



LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:120.25V I:0.1012A P:11.967W PF:0.9836 Freq:60.00Hz Lamp Flux:895.686x1 lm		
NAME: IP65 Trimless 12W LED Pot Light	TYPE:	WEIGHT:
SPEC.: LP-SP04-IP-C12-01 RA>903000K	DIM.:	SERIAL No.:
MFR.: Lumen Paul	SUR.:	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA				Eff: 74.84 lm/W
MODEL		Imax (cd)	1950	S/MH (C0/180)		0.61
NOMINAL POWER(W)	--	LOR (%)	100.0	S/MH (C90/270)		0.63
RATED VOLTAGE (V)	--	TOTAL FLUX(lm)	895.69	η UP,DN (C0-180)		0.0,50.0
NOMINAL FLUX(lm)	895.686	CIE CLASS	DIRECT	η UP,DN (C180-360)		0.0,50.0
LAMPS INSIDE	1	η up (%)	0.0	CIBSE SHR NOM		0.50
TEST VOLTAGE (V)	--	η down (%)	100.0	CIBSE SHR MAX		0.65

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
C Interval: 15.0DEG
Test Speed: 10.0deg/s
Temperature:25.3°C
Operators:
Test Date:2025-09-06

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-3000H_V1 SYSTEM V2.00.463
Humidity:65.0%
Test Distance:9.000m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	%lum,lamp
10	1663	1618	1559	1535	1592	1637	1680	1682	0~ 10	169.5	169.5	18.9,18.9
20	899.1	918.8	886.3	868.1	893.7	908.4	926.4	907.6	10~ 20	348.9	518.4	57.9,57.9
30	261.8	313.6	319.0	316.0	305.0	280.9	277.9	257.1	20~ 30	256.4	774.7	86.5,86.5
40	47.23	68.76	72.07	63.83	59.88	60.21	59.13	47.60	30~ 40	88.86	863.6	96.4,96.4
50	9.962	13.31	15.05	12.83	12.19	12.03	10.99	9.772	40~ 50	23.09	886.7	99,99
60	3.346	3.462	3.538	3.451	3.486	3.460	3.430	3.382	50~ 60	4.774	891.5	99.5,99.5
70	1.934	2.307	2.143	2.307	2.126	2.279	2.012	2.195	60~ 70	2.878	894.4	99.9,99.9
80	0.3488	0.4314	0.3702	0.4058	0.3688	0.4126	0.3612	0.4177	70~ 80	1.163	895.5	100,100
90	0.1334	0.1013	0.0622	0.0582	0.0522	0.0582	0.0612	0.1003	80~ 90	0.1724	895.7	100,100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

Conical surface Flux(90deg): 878.8 lm

%lum = 98.1%

%lamp = 98.1%

Conical surface Flux(120deg): 891.47 lm


%lum = 99.5%

%lamp = 99.5%

C Range: 0 - 360DEG
C Interval: 15.0DEG
Test Speed: 10.0deg/s
Temperature:25.3℃
Operators:
Test Date:2025-09-06

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 γ Test System:EVERFINE GO-3000H_V1 SYSTEM V2.00.463
Humidity:65.0%
Test Distance:9.000m [K=1.0000]
Remarks:

LUMINANCE LIMITATION CURVES




LUMINANCE cd/(m2)		
G (DEG)	C0/180	C90/270
85	429	352
80	609	646
75	1042	1131
70	1714	1898
65	2076	2172
60	2028	2144
55	2095	2289
50	4696	7096
45	9904	14513

C Range: 0 - 360DEG
C Interval: 15.0DEG
Test Speed: 10.0deg/s
Temperature: 25.3°C
Operators:
Test Date: 2025-09-06

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System: EVERFINE GO-3000H_V1 SYSTEM V2.00.463
Humidity: 65.0%
Test Distance: 9.000m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Coefficients of Utilization(CU)									
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00
1.0	1.12	1.10	1.08	1.10	1.08	1.06	1.06	1.04	1.03	1.02	1.01	.00	.99	.98	.97	.95
2.0	1.05	1.02	.99	1.04	1.00	.98	1.00	.98	.96	.97	.95	.93	.95	.93	.92	.90
3.0	.99	.95	.92	.98	.94	.91	.96	.92	.90	.93	.90	.88	.91	.89	.87	.85
4.0	.94	.89	.86	.93	.89	.85	.91	.87	.84	.89	.86	.83	.87	.85	.82	.81
5.0	.89	.84	.81	.89	.84	.80	.87	.83	.80	.85	.82	.79	.84	.81	.78	.77
6.0	.85	.80	.76	.84	.80	.76	.83	.79	.76	.82	.78	.75	.80	.77	.75	.73
7.0	.81	.76	.73	.81	.76	.72	.79	.75	.72	.78	.74	.72	.77	.74	.71	.70
8.0	.78	.73	.69	.77	.72	.69	.76	.72	.69	.75	.71	.68	.74	.71	.68	.67
9.0	.74	.69	.66	.74	.69	.66	.73	.69	.66	.72	.68	.65	.71	.68	.65	.64
10.0	.71	.66	.63	.71	.66	.63	.70	.66	.63	.69	.65	.63	.69	.65	.62	.61



C Range: 0 - 360DEG
C Interval: 15.0DEG
Test Speed: 10.0deg/s
Temperature:25.3°C
Operators:
Test Date:2025-09-06

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-3000H_V1 SYSTEM V2.00.463
Humidity:65.0%
Test Distance:9.000m [K=1.0000]
Remarks:

WEC AND CCEC

pcc	80%			70%			50%			30%			10%			0	
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
pfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients (WEC)										
0.0																	
1.0	.159	.090	.029	.152	.087	.028	.139	.080	.026	.128	.074	.024	.117	.068	.022		
2.0	.150	.082	.025	.144	.079	.024	.134	.074	.023	.124	.070	.022	.115	.065	.021		
3.0	.141	.075	.023	.137	.073	.022	.128	.069	.021	.120	.066	.020	.112	.062	.019		
4.0	.134	.070	.020	.130	.068	.020	.122	.065	.019	.115	.062	.019	.109	.059	.018		
5.0	.127	.065	.019	.124	.064	.019	.117	.061	.018	.111	.059	.017	.106	.056	.017		
6.0	.121	.061	.017	.118	.060	.017	.113	.058	.017	.107	.056	.016	.102	.054	.016		
7.0	.116	.057	.016	.113	.056	.016	.108	.055	.016	.103	.053	.015	.099	.051	.015		
8.0	.111	.054	.015	.108	.053	.015	.104	.052	.015	.100	.051	.015	.096	.049	.014		
9.0	.106	.051	.014	.104	.051	.014	.100	.050	.014	.096	.048	.014	.093	.047	.014		
10.0	.102	.049	.014	.100	.048	.013	.097	.047	.013	.093	.046	.013	.090	.045	.013		

pcc	80%			70%			50%			30%			10%			0	
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
pfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients (CCEC)										
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020		
1.0	.170	.157	.146	.145	.135	.126	.099	.093	.087	.057	.054	.051	.018	.017	.016		
2.0	.153	.133	.115	.131	.114	.100	.090	.079	.069	.052	.046	.041	.017	.015	.013		
3.0	.140	.113	.092	.120	.098	.080	.082	.068	.056	.047	.040	.033	.015	.013	.011		
4.0	.128	.098	.075	.110	.085	.066	.076	.059	.046	.044	.035	.027	.014	.011	.009		
5.0	.119	.086	.063	.102	.075	.054	.070	.052	.038	.041	.031	.023	.013	.010	.008		
6.0	.111	.077	.052	.095	.067	.046	.066	.047	.032	.038	.027	.019	.012	.009	.006		
7.0	.104	.069	.045	.089	.060	.039	.062	.042	.028	.036	.025	.016	.012	.008	.005		
8.0	.098	.063	.038	.084	.054	.033	.058	.038	.024	.034	.022	.014	.011	.007	.005		
9.0	.093	.057	.033	.080	.050	.029	.055	.035	.021	.032	.021	.012	.010	.007	.004		
10.0	.088	.053	.029	.076	.046	.025	.053	.032	.018	.031	.019	.011	.010	.006	.004		

C Range: 0 - 360DEG
C Interval: 15.0DEG
Test Speed: 10.0deg/s
Temperature:25.3℃
Operators:
Test Date:2025-09-06

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-3000H_V1 SYSTEM V2.00.463
Humidity:65.0%
Test Distance:9.000m [K=1.0000]
Remarks:

UGR(Unified Glare Rating) Table

ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
x = 2H y = 2H	14.2	15.1	14.5	15.2	15.4	15.9	16.7	16.1	16.8	17.0
3H	14.2	14.9	14.4	15.1	15.3	15.8	16.5	16.0	16.7	16.9
4H	14.1	14.8	14.4	15.0	15.2	15.7	16.4	16.0	16.6	16.8
6H	14.0	14.7	14.3	14.9	15.2	15.6	16.3	15.9	16.5	16.8
8H	14.0	14.6	14.3	14.9	15.1	15.6	16.2	15.9	16.5	16.7
12H	13.9	14.6	14.3	14.8	15.1	15.5	16.1	15.8	16.4	16.7
4H 2H	14.0	14.8	14.3	15.0	15.2	15.6	16.4	15.9	16.6	16.8
3H	14.0	14.6	14.3	14.9	15.1	15.6	16.2	15.9	16.4	16.7
4H	13.9	14.5	14.3	14.8	15.1	15.5	16.0	15.8	16.3	16.6
6H	13.8	14.3	14.2	14.7	15.0	15.4	15.9	15.8	16.2	16.6
8H	13.8	14.3	14.2	14.6	15.0	15.3	15.8	15.7	16.2	16.5
12H	13.7	14.2	14.2	14.5	14.9	15.3	15.7	15.7	16.1	16.5
8H 4H	13.8	14.3	14.2	14.6	15.0	15.3	15.8	15.7	16.2	16.5
6H	13.7	14.1	14.1	14.5	14.9	15.3	15.6	15.7	16.0	16.4
8H	13.7	14.0	14.1	14.4	14.9	15.2	15.5	15.6	15.9	16.4
12H	13.6	13.9	14.1	14.3	14.8	15.1	15.4	15.6	15.9	16.3
12H 4H	13.8	14.2	14.2	14.5	14.9	15.3	15.7	15.7	16.1	16.5
6H	13.7	14.0	14.1	14.4	14.9	15.2	15.5	15.6	15.9	16.4
8H	13.6	13.9	14.1	14.3	14.8	15.1	15.4	15.6	15.9	16.3
Variations with the observer position at spacings(CIE Pub.117):										
S = 1.0H	+ 2.5 / - 6.9					+ 3.2 / - 8.3				
1.5H	+ 4.4 / - 6.9					+ 5.2 / - 8.5				
2.0H	+ 4.9 / - 3.0					+ 5.9 / - 4.4				

CIE Pub.117, 895.7 lm Total Lamp Luminous Flux Corrected (8log(F/F0) = -0.4)
Area: 0.0033 m2

C Range: 0 - 360DEG
C Interval: 15.0DEG
Test Speed: 10.0deg/s
Temperature:25.3°C
Operators:
Test Date:2025-09-06

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-3000H_V1 SYSTEM V2.00.463
Humidity:65.0%
Test Distance:9.000m [K=1.0000]
Remarks:


UTILIZATION FACTORS TABLE

REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS (PERCENT) $k(RI) \times RCR = 5$									
$k = 0.60$	89	83	80	89	83	80	88	83	80	76
0.80	97	91	88	96	91	87	95	90	87	84
1.00	101	95	92	100	95	92	98	95	91	87
1.25	104	99	96	103	99	96	101	98	95	91
1.50	107	102	99	106	102	99	104	100	98	93
2.00	109	105	102	108	104	102	105	102	100	95
2.50	111	107	104	109	106	104	106	104	102	96
3.00	112	109	106	110	108	105	107	105	103	97
4.00	114	112	110	112	110	108	109	107	105	98
5.00	115	113	112	113	111	110	109	108	107	99
ROOM INDEX	UF (total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG
 C Interval: 15.0DEG
 Test Speed: 10.0deg/s
 Temperature: 25.3°C
 Operators:
 Test Date: 2025-09-06

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-3000H_V1 SYSTEM V2.00.463
 Humidity: 65.0%
 Test Distance: 9.000m [K=1.0000]
 Remarks:


ISOCANDELA DIAGRAM



C Range: 0 - 360DEG
C Interval: 15.0DEG
Test Speed: 10.0deg/s
Temperature: 25.3°C
Operators:
Test Date: 2025-09-06

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-3000H_V1 SYSTEM V2.00.463
Humidity: 65.0%
Test Distance: 9.000m [K=1.0000]
Remarks:

AAI Figure




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 15.0DEG
Test Speed: 10.0deg/s
Temperature:25.3℃
Operators:
Test Date:2025-09-06

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-3000H_V1 SYSTEM V2.00.463
Humidity:65.0%
Test Distance:9.000m [K=1.0000]
Remarks:

ISOLUX DIAGRAM



C Range: 0 - 360DEG
C Interval: 15.0DEG
Test Speed: 10.0deg/s
Temperature: 25.3°C
Operators:
Test Date: 2025-09-06

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System: EVERFINE GO-3000H_V1 SYSTEM V2.00.463
Humidity: 65.0%
Test Distance: 9.000m [K=1.0000]
Remarks:

LED Avg.L Report

Test:U:120.25V I:0.1012A P:11.967W PF:0.9836 Freq:60.00Hz Lamp Flux:895.686x1 lm		
NAME: IP65 Trimless 12W LED Pot Light	TYPE:	WEIGHT:
SPEC.: LP-SP04-IP-C12-01 RA>903000K	DIM.:	SERIAL No.:
MFR.: Lumen Paul	SUR.:	Shielding Angle:


AvgL	cd/m2
L_0~180 (65) av	2108
L_0~180 (75) av	1090
L_0~180 (85) av	378
L_90~270 (65) av	2148
L_90~270 (75) av	1112
L_90~270 (85) av	340
L_45 (65) av	2121
L_45 (75) av	1303
L_45 (85) av	419

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
C Interval: 15.0DEG
Test Speed: 10.0deg/s
Temperature:25.3℃
Operators:
Test Date:2025-09-06

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-3000H_V1 SYSTEM V2.00.463
Humidity:65.0%
Test Distance:9.000m [K=1.0000]
Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 15.0DEG
Test Speed: 10.0deg/s
Temperature: 25.3°C
Operators:
Test Date: 2025-09-06

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-3000H_V1 SYSTEM V2.00.463
Humidity: 65.0%
Test Distance: 9.000m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Table--1

UNIT: cd

[illegible]

C Range: 0 - 360DEG
C Interval: 15.0DEG
Test Speed: 10.0deg/s
Temperature: 25.3°C
Operators:
Test Date: 2025-09-06

```

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-3000H_V1 SYSTEM V2.00.463
Humidity:65.0%
Test Distance:9.000m [K=1.0000]
Remarks:

```

